

VOC Content Test Certificate

Friday November 28th, 2008

Supplier: Hilti Australia Pty Ltd

1G Homebush Bay Drive

Rhodes NSW 2138

Sample Description: CP606 intumescent joint sealant

Date Tested: November 2008

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

| | |
|---|---|
| Specification Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11 | Hilti CP606 |
| Architectural Sealant 250 grams per Litre as VOC content material | 63 grams per Litre as VOC content per coating |
| Specification Green Building Council of Australia Green Star Office Design V3 IEQ-13 | Hilti CP606 |
| Architectural Sealant 250 grams per Litre as VOC content material | 63 grams per Litre as VOC content per coating |



Dr. Vyt Garnys
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ
 ACA, AIRAH, FMA
 Managing Director and Principal Consultant

F0811-20