

# VOC Content Test Certificate

Monday August 25<sup>th</sup>, 2008

Supplier: Hilti (New Zealand) Limited

Unit B, 750 Great South Road

Penrose, Auckland New Zealand

Sample Description: CP 611A intumescent sealant

Date Tested: August 2008

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

<b>Specification</b> <b>Green Building Council of Australia</b> <b>Green Star Office Design IEQ-13</b> <b>Green Star Office Interiors IEQ-11</b>	<b>Hilti CP 611A</b>
Architectural Sealant 250 grams per Litre	<b>175 grams per Litre</b>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant

F0808-22