

VOC Content Test Certificate

Friday November 28th, 2008

Supplier: Hilti Australia Pty Ltd

1G Homebush Bay Drive

Rhodes NSW 2138

Sample Description: CP601S elastic firestop sealant

Date Tested: November 2008

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11	Hilti CP601S
Architectural Sealant 250 grams per Litre as VOC content material	27 grams per Litre as VOC content per coating
Specification Green Building Council of Australia Green Star Office Design V3 IEQ-13	Hilti CP601S
Architectural Sealant 250 grams per Litre as VOC content material	27 grams per Litre as VOC content per coating



Dr. Vyt Garnys
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ
 ACA, AIRAH, FMA
 Managing Director and Principal Consultant

F0811-20